600mm dia.

PRICE SCHEDULE

Tender for the Supply of Swing Check Valve (PN 25) 6 No's to delivery side of pumps in CWSS Stage III Pumping Station at T.K.Halli					
SL No.	**Specifications**	**Unit**	**Qty**	**Rate**	**Amount**
1	Supply of 600mm dia double flanged Swing/Slanted check valve (Non Return Valve) as per IS 5312 PN25 rating. **Material of Construction:** Supply of 600mm dia Double flanged swing/slanted type Check valve (Approved make) of PN 25 rating Design standard EN 12334 and EN 1074-3 Face to face EN 558 series flange drilling EN 1092 Testing standard EN 12266 with following M.O.C: Body & Disc- Ductile Iron Grade 400-15, Shaft: Stainless Steel EN 10088-11.4021/AISI 410 Retaining ring :carbon steel ST37, Bearing: Bronze, Sealing ring: EPDM, Internal Hardware: A2 stainless steel with valve coating of epoxy, powder coating in blue color and coating thickness of 250 microns DFT. valves shall be suitable for a maximum Working pressure of 25Kg/Cm²(Seat Test) and body tested to 37.5Kg/cm². Generally	Nos	6.		

↑but Excluding GST.

Note: The rate shall be inclusive of all applicable taxes & duties, insurance, transportation, Loading & Unloading and any incidentals

AE

"Approved"

EE (K-O&M)-1

Executive Engineer
Kaveri -Operation & Maintenance-1
BWSSB T.K. Halli-571421

"Draft Tender papers from page no. ① to (44) along with a price schedule for the work of Supply of 600mm dia Swing check valve (PN-25) 6Nos to delivery side of pumps in CWSS stage IV pumping station is Approved as corrected."

Additional Chief Engineer
(Kaveri O&M)-1,
Bangalore Water Supply
and Sewerage Board
Harohalli, Ramanagara Dist-562 112

Chief Engineer
(Kaveri -Operation & Maintainance)
BWSSB, 6th Floor,
Cauvery Bhavan, K.G. Road,
Bengaluru - 560 009